

Oliver Healthcare Packaging Spurkt 1 5804 AR Venray

Cleanroom 2 is compliant with:

- NEN-EN-ISO 14644-1: 2016
- ISO Class 7 at-rest
- ISO Class 8 operational

The performed measurements:

- Are according to NEN-EN-ISO 14644:1-2016
- Are according to NEN-EN-ISO 14644:3-2019
- Are executed by certified engineers
- Are stated in report Q-121864

All validations executed on the 26th of January 2024 Certificate expires: 26th of January 2025

Validation Company:

IMI Aero-Dynamiek b.v. Databankweg 7 3821 AL Amersfoort

C. van Dee, Engineer Validation department.

